



**Temporary Field Storage Containers Must Be Marked With:**

- Name of Owner
- Capacity of Container
- I.D. Number
- Contents
- NFPA diamond

**An application tank that is functionally connected to and dedicated solely for use with a chemigation or fertigation operation is exempt from the Secondary and Operational Area Containment Rules.**

